



## **Invitation to Negotiate** **Q&A Clay County Facility**

Pace Center for Girls, Inc., a Florida not-for-profit corporation ("Pace"), is seeking competitive responses from qualified vendors ("Vendors") interested in the Invitation to Negotiate ("ITN") to construct a facility in Clay County. The following questions have been presented to date.

1. **Can Core-fill foam be used to fill empty masonry cells in lieu of loose fill insulation as noted 1/A.04B?**

*Yes, core-fill foam can be used in lieu of loose fill insulation.*

2. **Please confirm a 5/8" drywall layer is to be applied to the bottom of the wood trusses to forma plenum and that the return air is to be ducted through this layer of drywall. It is also questionable whether some of the air handlers will fit in locations shown, especially AH-6 and AH-9 with dimensions of 54Hx49Wx 26D which will also fit through the truss spacing.**

*Return to be ducted, no drywall for plenum. Clarifications of ducted returns to follow with revised drawing.*

3. **What is the expected date at this time since 11/1/2019 has come and gone?**

*Unknown at this time.*